



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/02/2026

Incharge(s): Lal Singh,Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VF-23	M2 TRIPPED CABLE CUT	CABLE JOINT DONE AND RESET	19:50:00	20:15:00	
2	OHP	CO-5A	BRS MALFUNCTION	SENSOR FIXED PROPERLY THEN OK	20:10:00	20:30:00	
3	CHP	CC-39 SCR-6	LT M3 TRIPPED	RESET DONE	21:05:00	21:15:00	
4	CHP	CC-51	MPD TRIPPED 8 TIMES	RESET DONE	17:30:00	21:45:00	
5	CHP	CC-54	TRIPPED ON OLR	RESET DONE	21:23:00	21:27:00	
6	CHP	RG-3 FG	FG MOTOR TRIPPED	RESET DONE	21:30:00	21:40:00	