



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/07/2025

Area: OHP

Equipment	Job
cr-2a	motor is replaced and testing done, bearing end shield danged motor shifted to ers.
co-8a,db-1	io bits were arranged as per new io list