



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/01/2026

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-20	Right boom ZSS acting	Return idler missing.	11:30:00	11:40:00	Informed to mechanical and bypassed as per operation request
2	OHP	OM-12 and Daybins all conveyors red	1-141LC3 I/C-2 tripped	Old joint opened for TT-1A I/C made on switching off power for TT-1A.	11:50:00	12:10:00	Permanent joint done for TT-1A cable
3	CHP	CC-34 SCR-1	Reported no operations taking place	Checked and found output card failed in PLC rack.Card replaced and tested okay	06:00:00	09:10:00	
4	CHP	CC-216	Reported tripped	OLR acted.Reset done	07:55:00	08:05:00	
5	CHP	CC-35 SCR-3	B/C not running	Mains and control not made on.Made on and tested okay	08:10:00	08:20:00	
6	CHP	CC-108	Reported tripped	OLR acted.Reset done(2 times)	09:00:00	09:35:00	
7	CHP	Cc-32 SCR-5	Communication problem	ZSS cage probe replaced and tested okay	12:00:00	12:20:00	
8	WT	OC-1A	ZSS acted	Probe and cage replaced and tested okay	08:45:00	09:20:00	
9	WT	OT-4	Reported tripped	Drive-2 tripped on PGEF-4 fault.	13:15:00	13:25:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/01/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	IOSA	Reported all conveyors communication problem	communication problem between LC'S	Attended by general shift..GBC converter changed for 1-142LC-2 GE PLC and OFC to GBC converter kept off in LC-3 and LC-1 and tested okay	06:00:00 09:10:00	07:50:00 09:50:00	