



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/02/2026

Area: WT

Equipment	Job
OT 2 and 3 series	Panel and Motor side ppm done
OP 9	Pane and Motor side ppm done
OP 10	welding work completed ,inside room lighting done and clearance given
OT 3	cable laying done for both the Motor Encoders from drive panel
MIS	240V control supply provided with MCB control for camera @ OT 1,2 and 3
OP2,4,5,7 and 9	After rake maintenance done