



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 13/01/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC 4 ON CC 28 LT	DRIVE HEALTHY AND DRIVE ON FEEDBACK COMMON FUSE BLOWN	REPLACED	03:00:00 05:30:00	03:45:00 05:50:00	
2	OHP	BRC 3 ON CO 33M	CHUTE SENSOR	KEPT IN CIRCUIT	22:30:00	23:00:00	
3	OHP	CO 33M	OLR ACTED	RESET	23:00:00	23:10:00	
4	OHP	WBR ON CO 26	PCRD O/T ACTED	RELEASED	00:00:00	00:15:00	
5	OHP	CO 26	OLR ACTED	RESET	00:05:00 00:55:00 03:10:00	00:15:00 01:05:00 03:15:00	
6	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	22:30:00	05:30:00	22 TIMES
7	CHP	CC 131	OLR ACTED	RESET	03:41:00 05:35:00	03:45:00 05:40:00	
8	CHP	SCR 3 ON CC 35	B/C OLR ACTED	RESET	01:50:00	02:00:00	
9	CHP	CC107	OLR ACTED	RESET	05:20:00	05:30:00	
10	CHP	CC 204	OLR ACTED	RESET	05:30:00	05:40:00	
11	WT	OT2	D2 TRIPPED ON PGF1 FAULT	RESET	03:45:00 23:00:00	03:50:00 23:10:00	