



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/09/2025

Area: WT

Equipment	Job
CP 3	panel and motor side ppm done
OT 4 cabin	one tube light installed and provided mcb
CO 2	area lighting and socket supply rectified
CO 3 and 4	stair case area and CO 3 area lighting problems rectified
EOT Crane(O)	Main hoist Break supply,checked and rectified
OP 9	Trolley line inspection done ,col 25 section area,all bus bar adjusted
OP 8 and CP 2	After rake maintenance done