



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/11/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11A FAIL TO START	K16 RELAY PROBLEM	REPLACED THEN OK	03:00:00	04:30:00	
2	OHP	BRC ON CO 28 LT	DRIVE TRIPPED ON OVER CURRENT	RESET	22:30:00	22:40:00	
3	OHP	TBS ON CO 20 LT	M1 TRIPPING FREQUENTLY	MOTOR DISCONNECTED	22:45:00	23:30:00	
4	OHP	WBR ON CO 29 LT	M3 TRIP	MADE IT ON	00:35:00	00:50:00	
5	OHP	BRC ON CO 28	MAIN CONTROL TRIPPED	MADE IT ON	01:10:00	01:35:00	
6	OHP	CO 26	OLR ACTED	RESET	01:55:00	02:05:00	
7	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	00:50:00	04:50:00	15 TIMES
8	CHP	CC 51	OLR ACTED	RESET	02:35:00	02:45:00	
9	CHP	CC 125	OLR ACTED	RESET	01:00:00 05:00:00	01:05:00 05:10:00	
10	CHP	SCR 6 ON CC 38 B/C	OLR ACTED DUE TO JAMMING	RESET	01:55:00	02:10:00	
11	CHP	SCR 6 ON CC 38 B/C SIGNAL MISSING IN REC MODE	YARD RUNNING COMMUNICATION BIT MADE HIGH	THEN OK	04:55:00	05:10:00	REMOVED AFTER SOME TIME



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC 113A	OLR ACTED	RESET	05:45:00	05:55:00	
13	WT	OP3 NOT MOVING	M5 ROTOR CONTACTOR STUCK	MADE IT FREE	05:15:00	05:25:00	