



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/10/2025

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-29	Reported Luffing not taking place	Down limit acted.Released and tested okay	07:00:00	07:20:00	
2	OHP	BRC on CO-30	LT not taking place	Skew limit acted.	08:20:00	09:20:00	Adjusted along with mechanical
3	OHP	BRC on CO-32	B/C tripped	OLR acted.Reset done	08:30:00 10:00:00	08:40:00 10:30:00	
4	OHP	WOBR on CO-26	Reported Slewing not taking place	Drive tripped.Reset done	10:00:00	10:20:00	
5	OHP	BRC on CO-30	Reported CT not taking place	CT chain fallen.	13:30:00	13:45:00	Informed to mechanical
6	OHP	BRC on CO-30	B/C tripped	OLR acted.Reset done	10:10:00	10:20:00	
7	OHP	TT-1A	CJD not getting reset	Material jamming found	10:30:00	10:40:00	Informed to operation
8	CHP	CC-117	Reported tripped	OLR acted.Reset done	11:50:00 12:55:00	11:55:00 13:00:00	
9	CHP	CC-23	Reported ZSS acting	Checked and found module settings not proper.Settings adjusted and tested okay	10:20:00	10:35:00	
10	CHP	CC-39 S-1	LT not taking place	PCRD overtension.Released and tested okay	06:48:00	07:00:00	
11	CHP	CC-32 R-1	B/C not running.	ZSS interlock cage stuck.Made free and tested okay	07:50:00	08:00:00	
12	CHP	CC-39	Reported tripped	OLR acted.Reset done	06:55:00	06:58:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/10/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-104 SCR-9	Reported no drives working	Breaker tripped.Made on	08:43:00	08:50:00	
14	CHP	CC-41	ZSS cable cut	ZSS cable joint done	09:10:00	09:20:00	
15	CHP	CC-38 SCR-6	LT not taking place	Drive Tripped.Reset done	09:35:00	09:45:00	
16	CHP	CC-36 SCR-1	Slew and luff not working	oil leakage from tank.	11:20:00	11:30:00	Informed to mechanical
17	CHP	CC-34 SCR-2	LT not working	Overtension acted.Released and tested okay	13:20:00	13:30:00	
18	CHP	CC-112 SCR-8	Reported slewing not taking place	Checked and found no oil in tank	08:00:00	08:20:00	Informed to mechanical
19	WT	OP-5	Reported not moving	Checked and found pusher in decoupled condition.	07:20:00	07:30:00	Informed to operation
20	WT	CO-3	Reported tripped	OLR acted.Reset done	11:00:00 12:35:00	11:10:00 12:45:00	