



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/11/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-1A	TRIPPED ON OLR (3TIMES)	RESET DONE	10:20:00 11:20:00 12:40:00	10:30:00 11:30:00 12:50:00	
2	OHP	BRC ON CO-30	REPORTED B/C NOT RUNNING CHECKED BIG STONE STUCK UP WITH B/W-2	B/C PHASE SEQUENCE CHANGED AND RUN R/D THAN OK AGAIN KEPT ORIGINAL	11:15:00	11:35:00	
3	OHP	TBS ON CO-7A	REPORTED LT NOT TAKING PLACE FOUND R/H INDICATION MISSING	LIMIT PROPERLY TIE WITH ROPE THAN OK	11:50:00	12:15:00	
4	CHP	CC-29	TRIPPED ON OLR (4TIMES)DUE TO JAMMING	RESET DONE	09:50:00	13:10:00	
5	CHP	CC-51	MPD TRIPPED (3TIMES) FEEDING CONVEYOR	RESET DONE	07:15:00	10:45:00	
6	CHP	TT ON CC-53	LT TRIPPED ON OLR	RESET DONE	08:30:00	08:45:00	
7	CHP	CC-213	YARD NOT RUNNING FOUND C/S ACTED DUE TO JAMMING	AFTER CLEAR THE MATERIAL THAN OK	08:30:00	09:00:00	
8	CHP	CC-38 SCR-6	SLEW NOT WORKING SLEW LIMIT ACTED	RELEASED	08:50:00	09:00:00	
9	CHP	CC-39 SCR-2	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED THAN OK	08:50:00	09:00:00	
10	CHP	CC-213	PC ACTED	PULL CHORD BYPASSED	11:05:00	11:15:00	
11	CHP	CC-39 SCR-2	REPORTED B/C NOT RUNNING C/S ACTED	RESET DONE	10:30:00	10:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-39 SCR-2	B/C NOT RUNNING SELECTION PROBLEM	KEPT CORRECT POSITION	12:35:00	12:45:00	
13	CHP	CC-32 R-1	B/C NOT RUNNING INTERLOCK CAGE STUCK UP WITH COAL PICK	REMOVED	12:45:00	13:00:00	
14	CHP	CC-39 SCR-2	LT PCRD O/T ACTED	RELEASED	13:30:00	13:40:00	