



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/08/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	Co 26	olr acted	reset	18:00:00	18:10:00	
2	OHP	VF 10 A	reported red,drive trip in overload	reset	17:20:00	17:30:00	
3	OHP	CO 35	olr acted	reset	20:00:00	20:10:00	
4	OHP	CO 87	olr acted	reset	19:30:00	19:35:00	
5	CHP	cc113	zss acted, due to jamming	informed operation	16:30:00	16:35:00	
6	CHP	cc 51	olr acted	reset	15:45:00	15:50:00	
7	CHP	CC 114	zss acted due to jamming	informed operation	16:40:00	16:50:00	
8	CHP	CC 31 R1	b/c not running,zss interlock cage stucked	cage made free	20:15:00	20:30:00	
9	CHP	cc 107	olr acted	reset	21:00:00	21:10:00	
10	IOSA	sco 1A	olr acted	reset	16:45:00	16:50:00	
11	IOSA	new WOBR	SLEW NOT TAKING PLACE,right limit acted	limit released,	21:40:00	22:00:00	still not slewing working,work going on