



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2025

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-9	Reported tripped	OLR acted.Reset done	06:28:00	06:33:00	
2	OHP	CO-15	Reported tripped	MPR tripped.Reset done	07:43:00	08:10:00	
3	OHP	CO-11(C/D)	Reported not moving	MPCB tripped.Made on	07:10:00	07:14:00	
4	OHP	BRC on CO-33M	Reported LT not taking place	PCRD tension acted.Released and tested okay	08:00:00	08:30:00	
5	CHP	CC-21(C/D)	Reported not moving	OLR acted.Reset done	09:00:00	09:10:00	
6	CHP	CC-27A	Reported chute sensor not getting reset	Bypassed at I/O rack	08:30:00	08:40:00	
7	CHP	CC-51	Feeding conveyor stopped	MPR acted.Reset done	10:15:00	10:20:00	
8	CHP	CC-34 SCR-2	Reported slewing not taking place	slew limit acted.Released and tested okay	06:35:00	06:45:00	
9	CHP	CC-36 SCR-1	Luffing down not taking place	Down limit acted.Bypassed as per operation request	07:45:00	07:55:00	
10	CHP	CC-38 SCR-6	TUL C/S acting frequently	Bypassed as per operation request	07:45:00	07:55:00	
11	CHP	CC-29 SCR-3	LT not working	Drive tripped.Reset done	11:10:00	11:20:00	
12	CHP	CC-39 SCR-3	LT not working	unloader jamming.Informed to operation	13:00:00	13:10:00	
13	CHP	CC-31 SCR-4	Reported control supply off	Checked and found control cable damaged due to cleaning work.	11:00:00	13:00:00	Informed to general shift .Rectified



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-104 SCR-9	Slew and B/W not moving	OIL temperature high. oil cooler not getting on.OIL temperature high bypassed at I/O rack	12:40:00	13:00:00	
15	IOSA	WOBR	Reported control getting on	LT limit switch damaged.Bypassed at I/o rack and made on.	10:10:00	10:20:00	