



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/10/2025

Shift: A

Incharge(s): Amit Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---------------------------------|--|----------------------|----------------------|--|
| 1 | OHP | CO-10A | Reported tripped | OLR acted.Reset done | 07:05:00 | 07:15:00 | |
| 2 | OHP | TBS on CO-7A | Reported Right boom not running | ACB tripped due to material jamming in chute | 09:35:00 | 09:50:00 | Material cleared and tested okay |
| 3 | OHP | TBS on CO-7A | LT not taking place | M2 MPCB tripped.Motor checked and found burnt.M2 kept out of circuit | 10:00:00 | 10:20:00 | M2 motor to be changed |
| 4 | CHP | CC-54 | Reported tripped | OLR acted.Reset done | 11:25:00 11:45:00 | 11:35:00 11:55:00 | |
| 5 | CHP | CC-51 | Reported tripped | MPD acted(6 times).Reset done | 09:05:00 | 12:30:00 | Tripped at 9 .05,9.25,11.30,11.45, 12.15,12.30pm |
| 6 | CHP | CC-38 SCR-6 | Reported Slew not moving | Limit acted.Released and tested okay | 07:30:00 | 07:45:00 | |
| 7 | CHP | CC-33 SCR-5 | Reported LT not taking place | Drive tripped.Reset done and tested okay | 07:30:00 | 07:40:00 | |
| 8 | CHP | CC-36 SCR-1 | Reported Luffing not working | OLR acted.Reset done and tested okay | 07:45:00 | 08:00:00 | |
| 9 | CHP | CC-28(B/D) | Reported tripped | OLR acted.Reset done(2times) | 12:30:00 | 12:40:00 | |
| 10 | WT | OC-1A | Reported tripped | OLR acted.Reset done | 07:15:00 | 07:30:00 | |
| 11 | WT | SC0-1A | Reported not running | Contactorauxiliary block opened.Rectified and tested okay | 12:10:00 | 12:30:00 | |
| 12 | IOSA | TBS | CJD problem | CJD probe changed from left to right chute | 10:00:00 | 11:00:00 | |