



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 18/01/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-28	CT not taking place	Wrong complaint	15:00:00	15:20:00	
2	OHP	BRC on CO-33M	LT not taking place	PCRD tension acted. Released and tested okay	19:00:00	19:10:00	
3	OHP	Stacker on CO-21	Reported left luff tripping	Mechanical gearbox problem	16:10:00	16:40:00	Informed to operation
4	OHP	VF-2A	Reported motor base bolts missing	Bolts replaced(2 times) and found motor tripping on OLR. motor checked and found okay but motor-1 side tray material not moving freely	18:08:00	21:25:00	Mechanical side checking to be done
5	CHP	CC-29	Reported tripped	OLR acted. Reset done	21:25:00	21:30:00	
6	CHP	CC-107	Reported tripped	OLR acted. Reset done	16:15:00	16:20:00	
7	CHP	CC-39 SCR-6	Slew not working	SLew area coal jamming	20:50:00	21:00:00	Informed to operation
8	WT	OP-2,3,6	Reported not moving	Communication problem. PLC power recycled.	15:10:00	15:25:00	
9	IOSA	BRC	LT not taking place in auto	B/W-1 OLR acted. Reset done	20:00:00	20:15:00	