



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|---|----------|----------|------------------------|
| 1 | OHP | TBS on Co 22 | right BC not running,gear box problem | informed mechanical | 07:15:00 | 07:30:00 | |
| 2 | OHP | wobr on co 26 | LT not taking place,m1 olr acted | reset | 08:15:00 | 08:30:00 | |
| 3 | OHP | co 50 | OLR acted | reset | 09:45:00 | 09:55:00 | |
| 4 | OHP | CO 7 | PC acted,earth fault in pc,fuse TB blown | pc bypassed | 12:10:00 | 12:25:00 | informed General shift |
| 5 | CHP | CC 51 | mpd tripped 9 times | reset | 07:00:00 | 07:10:00 | |
| 6 | CHP | CC 117 | olr acted | reset | 07:05:00 | 07:15:00 | |
| 7 | CHP | CC 51 | OLR acted | reset | 09:10:00 | 09:15:00 | |
| 8 | CHP | CC 31 scr4 | slew not working, | fault reset done in operator cabin | 08:00:00 | 08:05:00 | |
| 9 | CHP | CC 31 SCR4 | b/w not working,retuen filter bit missing | return filter bypassed in program,informed mechanical | 08:20:00 | 08:40:00 | |
| 10 | CHP | C 32 | B/C not working,MPD tripped | reset | 08:45:00 | 09:00:00 | |