



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/10/2025

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment         | Problem                           | Action                    | From   | To   | Remarks |
|-------|------|-------------------|-----------------------------------|---------------------------|--|--|---------|
| 1     | OHP  | CO 29             | OLR ACTED                         | RESET                     | 07:30:00<br>08:30:00<br>08:55:00<br>12:00:00 | 07:40:00<br>08:40:00<br>09:00:00<br>12:10:00 |         |
| 2     | OHP  | CO 26             | OLR ACTED                         | RESET                     | 07:40:00<br>08:15:00                         | 07:50:00<br>08:25:00                         |         |
| 3     | OHP  | BRC ON<br>CO 34   | LT O/T ACTED DUE TO GUIDE PROBLEM | RELEASED INFORMED TO MECH | 08:30:00                                     | 08:40:00                                     |         |
| 4     | OHP  | BRC ON<br>CO 31   | B/C OLR ACTED                     | RESET                     | 09:40:00<br>10:50:00                         | 09:55:00<br>11:00:00                         |         |
| 5     | OHP  | WBR ON<br>CO 26   | SLEW DRIVE TRIPPED                | RESET                     | 10:40:00                                     | 10:50:00                                     |         |
| 6     | CHP  | SCR 6 ON<br>CC38  | LT DRIVE TRIPPED                  | RESET                     | 12:15:00<br>12:55:00                         | 12:25:00<br>13:00:00                         |         |
| 7     | CHP  | CC 31             | OLR ACTED                         | RESET                     | 12:30:00                                     | 12:35:00                                     |         |
| 8     | CHP  | SCR 3 ON<br>CC 35 | B/C OLR ACTED                     | RESET                     | 13:20:00                                     | 13:30:00                                     |         |
| 9     | CHP  | CC 29             | F/G OLR ACTED                     | RESET                     | 06:30:00<br>07:50:00                         | 06:35:00<br>08:00:00                         |         |
| 10    | CHP  | CC 117            | OLR ACTED                         | RESET                     | 10:40:00                                     | 10:50:00                                     |         |
| 11    | CHP  | CC 51             | FEEDING MPD TRIPPED               | RESET                     | 13:15:00                                     | 13:25:00                                     |         |
| 12    | CHP  | CC 51             | OLR ACTED                         | RESET                     | 12:45:00                                     | 12:50:00                                     |         |
| 13    | CHP  | CC 54             | OLR ACTED                         | RESET                     | 13:20:00                                     | 13:25:00                                     |         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/10/2025

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem                           | Action | From                 | To                   | Remarks                                  |
|-------|------|-----------|-----------------------------------|--------|----------------------|----------------------|--|
| 14    | WT   | AF4       | DRIVE TRIPPED DUE TO GROUND FAULT | RESET  | 12:00:00<br>12:20:00 | 12:05:00<br>13:00:00 | MOTOR ME<br>GGERED E<br>VERYTHIN<br>G OK |