



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/11/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done(2 times)	06:35:00 12:10:00	06:40:00 12:20:00	
2	OHP	CO-67	Reported tripped	OLR acted.Reset done	06:55:00	07:00:00	
3	CHP	Cc-51	Reported tripped	MPD acted.Reset done(7 times)	06:00:00	13:00:00	
4	CHP	Cc-54	Reported tripped	OLR acted.Reset done(19 times)	06:30:00	13:30:00	
5	CHP	CC 117	Reported tripped	OLR acted.Reset done	08:55:00	09:15:00	
6	CHP	Cc-19	Reported tripped	OLR acted.Reset done	07:20:00	07:25:00	
7	CHP	Cc-47	Reported fail to start	Power recycled and tested okay	07:20:00	07:31:00	
8	CHP	CC-33 SCR-5	Reported LT not working	Drive tripped.Reset done	07:33:00	07:44:00	
9	CHP	Cc-203	Reported tripped	OLR acted.Reset done	08:35:00	08:42:00	
10	CHP	Cc-48	Reported tripped	OLR acted due to heavy material on belt.Reset done	09:02:00	09:15:00	Informed to operation
11	CHP	Cc 31 SCR-4	B/C not healthy	Wrong complaint	08:45:00	08:55:00	
12	CHP	Cc-34 SCR-1	Reported luffing not taking place	OLR acted.Reset done	10:28:00	10:35:00	
13	CHP	CC-49	Reported ZSS acting	Cable joint checked and rectified and tested okay	12:15:00	12:31:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/11/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OT-5	Drive tripping	M2 tripping on short circuit fault(3times)	09:15:00	11:30:00	Motor checked, meggered and found okay
15	IOSA	BRC	CT not moving	Checked and found OLR acted. Reset done(2times)	08:45:00	10:10:00	