



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-15	OLR ACTED (2TIMES)	RESET DONE	16:30:00 18:00:00	16:40:00 18:10:00	
2	OHP	CO-67	OLR ACTED	RESET DONE	18:55:00	19:00:00	
3	OHP	TIS-3	REPORTED FAIL TO STOP CHECKED E/STOP ACTED	E/STOP RELEASED THAN OK	20:30:00	20:50:00	
4	OHP	WOBR ON CO-6A	REPORTED LT NOT TAKING PLACE CHECKED AND FOUND NO PROBLEM FIND OUT	DRIVE RESET WITH KEY PAD THAN OK	15:00:00	16:00:00	
5	OHP	CC-28	OLR ACTED	RESET DONE	20:45:00	20:55:00	
6	OHP	WOBR ON CO-29	LT NOT TAKING PLACE M-3 OLR ACTED	RESET DONE	21:30:00	21:45:00	
7	CHP	CC-34 SCR-2	LT NOT TAKING PLACE PCRD O/T ACTED (2TIMES)	RELEASED	16:30:00 19:00:00	16:50:00 19:20:00	
8	CHP	CC-34 SCR-2	B/C NOT RUNNING ZSS CAGE STUCK UP WITH COAL	COAL REMOVED THAN OK	18:25:00	18:45:00	
9	CHP	CC-31 SCR-4	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED THAN OK	20:20:00	20:30:00	
10	CHP	CC-31	OLR ACTED	RESET DONE	20:35:00	20:45:00	
11	CHP	CC-39 SCR-3	B/C NOT RUNNING SIGNAL PROBLEM	LT MOVE THAN OK	21:00:00	21:15:00	
12	CHP	cc-21 c/d	olr acted	reset done	17:10:00	17:15:00	
13	CHP	CC-51	OLR ACTED(5TIMES)	RESET DONE	15:00:00	21:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-54	OLR ACTED (6TIMES)	RESET DONE	19:20:00	20:40:00	
15	CHP	CC-132	OLR ACTED	RESET DONE	17:40:00	17:50:00	