



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 16/06/2025

Area: CHP

Equipment	Job
STKR-1	micrologix 1100 provided in drive panel removed
SCR-1	Boom position circuit checked and bypass removed
SCR-10,CC-126 GALLERY	lighting circuit rectification done
SCR-10	motors ppm done
SCR-10	micrologix-1400 replaced, communication checked and found ok
CC-41,47	Running inspection done
RG-2	minus level chute vibrator fixed and kept in circuit
VS-1,VF-1	panel and motor ppm done
RG-1	HT motor ppm done