



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 85	OLR ACTED DUE TO HEAVY LOAD ON MATERIAL	RESET	00:35:00 01:20:00 04:55:00	00:45:00 01:30:00 05:05:00	
2	CHP	CC 58	OLR ACTED	RESET	23:05:00	23:20:00	
3	CHP	CC 117	OLR ACTED	RESET	23:50:00	00:05:00	
4	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	04:00:00	04:20:00	3 TIMES
5	CHP	CC 52	FEEDING CONVEYOR MPD ACTED	RESET	23:55:00	00:00:00	
6	CHP	CC 131	OLR ACTED	RESET	04:45:00	04:50:00	
7	CHP	CC 54	OLR ACTED	RESET	23:55:00	04:10:00	4 TIMES
8	CHP	VF3	DRIVE TRIP	RESET	03:25:00	03:30:00	
9	CHP	SCR 9 ON CC 104	SLEW COOLING FAN TRIPPED	MADE IT ON THEN OK	02:30:00	02:40:00	
10	CHP	SCR 1 ON CC 34	LUFF LIMIT ACTED	RELEASED	02:55:00	03:10:00	