



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|-------------------------------|----------|----------|---------|
| 1 | OHP | tbs on co 7A | LT not working,LBC not upto reclaiming height | LbC kept at reclaiming height | 19:05:00 | 19:25:00 | |
| 2 | OHP | CO 8 | olr acted | reset | 20:00:00 | 20:10:00 | |
| 3 | OHP | RSCO 10 A | ZSS probe disturbed,due to material falling | probe adjusted | 18:30:00 | 18:40:00 | |
| 4 | CHP | CC 51 | MPD trips 3 times | reset | 16:50:00 | 17:25:00 | |
| 5 | CHP | cc 14 | ZSS acted ,mechanical problem,bend pulley stucked | informed mechanical | 16:40:00 | 16:50:00 | |