



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/01/2026

Area: CHP

Equipment	Job
CC 58	PPM was done
SCR 3,SCR7	Machine shiftings were done
CC 35	Burnt motor replaced with new one and trail run was taken