



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/01/2026

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 29 LT	DRIVE TRIPPED	RESET	06:45:00	07:00:00	
2	OHP	WBR ON CO 29 B/C	OLR ACTED	RESET	07:50:00	08:00:00	
3	OHP	WBR ON CO 25 LUFF	OLR ACTED	RESET	09:05:00	09:15:00	
4	OHP	BRC ON CO 29 LT and CT	SELECTOR SWITCH IN LOCAL	CHANGED TO REMOTE	11:20:00	11:30:00	
5	CHP	CC 28	OLR ACTED	RESET	08:45:00	08:50:00	
6	CHP	SCR 1 ON CC 36	PCRD CABLE ZIGZAG	WINDING DONE PROPERLY	10:30:00	10:50:00	
7	CHP	CC 216	OLR ACTED	RESET	11:15:00	11:25:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	06:45:00	09:10:00	6 TIMES
9	CHP	CC 54	OLR ACTED	RESET	08:25:00	11:30:00	5 TIMES