



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/02/2026

Area: OHP

| Equipment      | Job  |
|----------------|--|
| tbs-1 on co-22 | ppm is done.   |
| BRC-2 on co-31 | HT transformer is changed and tested. old transformer is shifted to hvmmc-1 and oil removed. |