



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/02/2026

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 29	slew not working,drive tripped	reset	09:10:00	09:25:00	
2	OHP	wobr on co 29	all drive not healthy	luff down limit acted,bypass and given up cmd	09:35:00	09:40:00	
3	OHP	co 25	olr acted	reset	09:30:00	09:35:00	
4	OHP	tbs on co 5A	Lrt not working,selector in local	kept in remote	06:20:00	06:35:00	
5	OHP	TBS on CO 5A	complaint given LT not stoping,BC stoppingbut yard conveyor not stopped	all ckt checked all found ok. antenna of wireless fallen on top surface,antenna fixed temporary	08:25:00	08:55:00	antennae to be fixed properly
6	OHP	CO 56	not running,emergency acted	emergency released	12:30:00	12:38:00	
7	CHP	CC 103	TT not working,incomer is in off	made it on	10:40:00	10:50:00	
8	CHP	CC 27 A	showing unhealthy,emergency stucked	emergency released	10:15:00	10:25:00	
9	CHP	C 32 SCr5	signal missing,zss cage interlock probe cable damaged	cable rejoined	07:40:00	07:55:00	
10	CHP	CC 51	mpd tripped 6 times	reset	06:45:00	06:50:00	
11	WT	OT 4	D2 tripped in PGF1 fault	reset	09:20:00	09:25:00	
12	IOSA	all conveyor	communication problem	power recycle in LBDS2 of NIU card	07:30:00 11:01:00	08:00:00 11:15:00	