



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/01/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 34	OLR ACTED	RESET	08:40:00	08:45:00	
2	OHP	CO 84	OLR ACTED	RESET	10:30:00	10:45:00	
3	OHP	CO 11 CD	OLR ACTED	RESET	07:25:00	07:30:00	
4	OHP	CO 12	OLR ACTED	RESET	07:20:00	07:25:00	
5	CHP	SCR 10 ON CC 105	LT PCRD O/T ACTED	RELEASED	08:30:00	08:45:00	
6	CHP	S 3 ON CC 111	OLD JOINT GOT FAILED	INFORMED TO DNW	11:45:00	12:00:00	
7	CHP	CC 51 A	OLR ACTED	RESET	10:55:00	12:00:00	5 TIMES
8	CHP	CC 117	OLR ACTED	RESET	07:45:00	08:00:00	
9	CHP	CC 114	OLR ACTED	RESET	10:10:00 13:30:00	10:20:00 13:35:00	
10	WT	OT 4	D2 TRIPPED	RESET	10:30:00	10:35:00	
11	WT	OT 2	D2 TRIPPED ON PGF1 FAULT	RESET	13:20:00	13:25:00	