



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/11/2025

Shift: C

Incharge(s): Lal Singh,Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT-4	LT NOT WORKING ...MPCB TRIPPED	MADE ON	00:45:00	01:15:00	
2	OHP	CO-28 BRC	LT NOT WORKING	ACB IN OFF ... MADE ON	00:35:00	00:50:00	
3	OHP	CO-26 WBR	BW TRIPPED ON OLR	RESET DONE	01:00:00	01:15:00	
4	OHP	CO-29 WBR	BC OLR ACTED	RESET DONE	03:15:00	03:25:00	
5	CHP	CC-54	tripped on mpd 14 times	RESET DONE	00:55:00	04:50:00	
6	CHP	CC-131	TRIPPED ON OLR	RESET DONE	05:20:00	05:25:00	
7	CHP	CC-114	TRIPPED ON OLR	RESET DONE	23:55:00	00:05:00	
8	CHP	cc-51	MPD ACTED	RESET DONE	00:30:00 01:20:00	00:35:00 01:25:00	
9	CHP	CC-112 S-3	LUFF AND SLEW NOT WORKING	LUFF OIL LOW INFORMED MECH... SLEW 30 DEGREE ACTED .	22:23:00	23:05:00	
10	CHP	CC-112 S-3	LT NOT WORKING	POTENTIOMETER PROBLEM ... KEYPED SPEED PROVIDED	01:40:00	02:00:00	TO BE CHANGED
11	CHP	CC-112 S-3	NO POWER	ACB TRIPPED ... MADE ON	02:50:00	03:24:00	
12	CHP	CC-112 S-3	LT NOT WORKING	OT ACTED .. RELEASED	23:35:00	23:50:00	
13	CHP	CC-31 SCR-4	LT NOT WORKING	OT ACTED ... RELEASED	03:25:00	03:40:00	
14	CHP	CC-222	DRIVE TRIPPING ON STALL FAULT	NO ELECTRICAL PROBLEM ... STARTED AFTER OVERLOAD MATERIAL REMOVAL	00:30:00	03:52:00	
15	WT	OT-5	D2 TRIPPED	RESET DONE	03:10:00	03:15:00	
16	IOSA	OC-3A	TRIPPED DUE TO OVER LOAD	RESET DONE	03:50:00	04:10:00	