



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/07/2025

Area: WT

Equipment	Job
OP 10	Creepers along trolly line removed bottom side from col no 15 to 3
OC 1A	Area lighting problem rectified ,200W and 35W LEDs replaced
OP 1 and 4	after rake maintenance done