



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	olr acted	reset	23:35:00	23:45:00	3
2	OHP	BRC 31	LT not taking	wrong complaint	00:00:00	00:30:00	
3	OHP	WOBR 25	slew not working, drive trips in overload	reset	01:10:00	01:20:00	
4	OHP	WOBR 26	slew not taking place, drive trips in overload	reset	03:05:00	03:20:00	
5	OHP	WOBR 26	b/w not running, zss cage stucked	cage released	04:44:00	05:00:00	
6	OHP	CO 29	olr acted	reset	05:40:00	05:45:00	
7	OHP	CO 16	not healthy, MPD parameter goes to initial state, operation kept in local and run many number of times	U mpd relay parameter reset	05:00:00	05:40:00	
8	CHP	CC 35 SCR2	LT not taking place M2mpcb trips	made it on	23:00:00	23:10:00	
9	CHP	CC 223	not running, cjs acted, after that found all healthy but power contactor C1 not picked up	replaced contactor with CC 214 spare	02:00:00	02:20:00	
10	CHP	CC 112 scr 8	left side slew not working, slew limit acted	wrong complain	01:30:00	01:40:00	
11	CHP	CC 131	overload acted	reset	01:40:00	01:45:00	
12	CHP	CC 31	ZSS acted, zss cage lifted by mech	cage released	05:20:00	05:25:00	
13	CHP	CC 38 SCR3	b/c not running, signal missing	ethernet cable unplug plug, modem power recycle than ok	05:00:00	05:30:00	
14	WT	OP9	no movement, communication problem	run in local than remote	22:15:00	22:30:00	no delay after rack completion