



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 25/11/2025

Area: CHP

Equipment	Job
SCR-3	PCRD panel OLR changed with MPCB
Lighting	LC-17,CM-17,CM-19,LC-18 MCC rooms lighting improved
SCR-8	machine shifted to CC-213
CC-108	ppm done
Lighting	JH-10 area Hoist approach area lighting arranged temporarily
Lighting	CM-28 outside building above 120w light connection given temporarily
CC-114	motor and panel ppm done