



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/07/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT 4 ON BYPASS 2	CHUTE POSITION SIGNAL LOOSE IN SENSOR TERMINATION/ TIGHTENED	CHUTE POSITION SIGNAL KEPT IN CKT	15:30:00	16:30:00	
2	OHP	tbs on co 21	It not taking place/m4 olr acted	reset done	18:45:00	18:55:00	
3	OHP	co 35	tripped on olr	reset done	15:40:00 16:30:00	15:45:00 16:35:00	
4	OHP	co 69	operation reuest brs kept inckt	done	14:50:00	15:00:00	
5	OHP	co 35a	tripped on olr	reset done	16:00:00 20:10:00	16:10:00 20:25:00	
6	OHP	co 26	tripped on olr	reset done	19:20:00	19:30:00	
7	OHP	tbs on co 7a	It not taking place	olr 2 reset done in drive panel	20:20:00	20:35:00	
8	OHP	vf 14	m2 tripped on olr/due to material fallen around the motor	reset done	14:50:00 17:35:00	15:00:00 17:45:00	
9	CHP	CC 29	TRIPPED ON OLR 2 TIMES	RESET DONE	15:50:00 16:30:00 18:15:00	16:00:00 16:35:00 18:25:00	
10	CHP	SCR 9 ON CC104	bc signalmissing	LT DONE THEN OK	16:30:00	16:45:00	
11	CHP	CC 54	TRIPPED ON OLR DUE TO JAMMING	RESET DONE	16:20:00 18:50:00	16:25:00 18:55:00	
12	CHP	VF 31/VF 2	DRIVE TRIP ON FO21 FAULT	RESET DONE DUE TO JAMMING	15:35:00	15:45:00	
13	CHP	cc 27,cc 48	operation clearance brs kept in ckt	done	16:25:00	16:56:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/07/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	scr 9 on cc104	bc signal missing	zss cage placed and kept in ckt	19:25:00	19:40:00	
15	CHP	cc 17	tripped on olr	reset done	19:00:00	19:05:00	
16	CHP	s1 on cc39	It not taking place/pcrd tension acted	tension released	14:30:00	14:40:00	
17	CHP	scr 9 on cc104	It not taking placepcrd tension acted	tension released	19:10:00	19:20:00	
18	CHP	s1 on cc39	slew not working/ wrong complaint	tesed ok	20:25:00	20:30:00	
19	CHP	scr 7 on cc 36	It not taking place/ pcrd tension acted	tension released	21:15:00	21:25:00	
20	WT	sco 1a b/d	tripped on olr	reset done	14:45:00	14:50:00	
21	WT	ot 2	drive 1 tripped on pgf fault	reset done	16:20:00	16:25:00	