



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/09/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment      | Problem   | Action                             | From     | To       | Remarks |
|-------|------|----------------|---|------------------------------------|----------|----------|---------|
| 1     | OHP  | CO 9           | OLr acted   | reset                              | 22:45:00 | 23:55:00 |         |
| 2     | OHP  | BRC on CO 34   | zss interlock not working, cjd acted                      | CJD sensor adjusted                | 00:05:00 | 00:20:00 |         |
| 3     | OHP  | BRC on CO 28   | yard conveyor zss interlock not working, loose connection | tightened module TBs               | 03:15:00 | 03:35:00 |         |
| 4     | CHP  | CC 28          | olr acted   | reset                              | 01:00:00 | 01:05:00 |         |
| 5     | CHP  | CC 51          | mpd trips   | reset it done                      | 22:30:00 | 06:00:00 | 4 times |
| 6     | CHP  | SCR 1 on CC 36 | luffing not working, OLR acted                            | reset                              | 23:37:00 | 23:50:00 |         |
| 7     | CHP  | SCR1 on CC 36  | CS acted due to rain                                      | cleaning done bypassed and removed | 02:00:00 | 02:10:00 |         |
| 8     | CHP  | SCR4 on CC31   | TUL bypassed as per operational request                   | bypassed and removed               | 00:59:00 | 01:05:00 |         |