



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/07/2025

Area: WT

Equipment	Job
OP7	NOT MOVING, MIDDLE and BOTTOM C-CLAMP FIXING MAST PLATES TOUCHING TO TROLLEY LINE INSULATOR SETS AT COLNO-13 , MIDDLE AND BOTTOM INSULATOR SETS ADJUSTED THEN OK
OP4	PPM DONE.