



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/06/2025

Area: CHP

Equipment	Job
CC 34, 105,50,S!,SCR 10	Running inspection was done
SCR 10	MODEM and Antenna fixed ,communication established with CCR and trail run was taken
CC 21	Carriage drive Brake adjusted
CCR	8 nos tube fixtures replaced and ckt problems rectified
CC 25/26 gallery	3 nos 200W led fixtures replaced
CC 13	Motor realigned
CC 13	New control cable connected at panel and control JB and tested all inputs
R 3	Conveyor piece provided to protect interlock cage from coal falling
CC 31	New control JB provided and control wiring done