



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/05/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-16 , 8A, 37A	REQUEST TO KEEP BRS IN CKT FROM OPR	KEPT IN CKT	06:00:00	06:30:00	
2	OHP	CO-35	TRIPPED ON OVER LOAD	RESET DONE	11:05:00 12:25:00	11:10:00 12:30:00	
3	OHP	CO-28 BRC	BC NOT STARTING	CHUT SENSOR ACTED DUE TO STONE STUCK UP ... REMOVED	12:20:00	12:40:00	
4	OHP	TBS ON CO -7A	LT NOT WORKING	LT BREAKS NEEDS TO BE ADJUSTED .... INFORMED MECH	10:00:00	10:15:00	
5	OHP	CO-20 TBS	LUFFING AND LT NOT WORKING	LUFF TRIPPED DUE TO BREAK PROBLEM ... BREAKS ADJUSTED WITH MECH... LT DONE AFTER LUFFING RECLAIMING HEIGHT	06:45:00	07:20:00	
6	OHP	CO-77	BELT SCALE OF CO-84 TO CO 77 BYPASS REQ	BYPASSED	14:00:00	14:10:00	
7	CHP	CC-107	BRS KEPT IN CIRCUIT	DONE	08:30:00	08:40:00	
8	CHP	CC-38 SCR-3	LT DRIVE AND MOTOR TRIPPED ON OVER LOAD	RESET DONE	07:30:00	07:50:00	
9	CHP	CC-105 SCR-10	BC NOT RUNNING	OLR ACTED RESET DONE ... SMOKE OBSERVED FROM GEARBOX INFORMED TO MECHANICAL	10:35:00	10:50:00	
10	CHP	CC-32 SCR-5	BC TRIPPED ON OVERLOAD	RESET DONE	12:00:00	12:20:00	
11	CHP	CC-34 SCR-2	LT OVER TENSION ACTED	RELEASED	12:10:00	12:30:00	