



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS2	OLR ACTED	RESET	22:30:00	22:35:00	
2	OHP	vs 1a	olr acted	reset	22:45:00	22:50:00	
3	OHP	co 84	olr acted	reset	00:15:00	00:25:00	
4	OHP	CO 26	olr acted	reset	01:45:00	01:55:00	
5	CHP	cc 36 S2	Lt not working.M1 tripped in OLR	reset	00:30:00	00:45:00	
6	CHP	CC 38 SCR 6	LT not working,,drive tripped in OLR,track jammed	reset	01:40:00	02:00:00	
7	CHP	CC 38 SCR6	signal missing	signal strength not good -91db,PLC and wireless power recycle in SCR	01:00:00	05:20:00	
8	CHP	CC 31 SCR4	b/w not running,LOW charge pressure problem	charge pressure bypassed	05:00:00	05:30:00	mechanical problem
9	CHP	CC 112 SCR8	b/c not running,mech gear box problem	informed operation and mechanical	03:50:00	04:05:00	
10	CHP	C 25 TT	LT not working,MPCb tripped	made it on	22:40:00	22:55:00	
11	WT	OT 1	D1 tripped in PGF1	reset	00:20:00	00:25:00	
12	WT	OT 5	clamp not working,	vertical and horizontal clamp pressure increased,39 and 52	01:35:00	01:55:00	
13	WT	SCO1A(C)	olr acted	reset	04:50:00	04:55:00	
14	IOSA	wobr old	b/c not running,yard zss interlock cage stucked with material	cage cleaned	23:40:00	23:50:00	