



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR acted	reset done	08:10:00	08:15:00	
2	OHP	WOBR on CO 6A	BW not running	Main breaker tripped, made on	08:50:00	09:05:00	
3	OHP	TT 1 on CO 7A	position bit missing	Fuse plug wire opened near 7A chute ,connect properly	08:20:00	08:30:00	
4	OHP	WOBR on CO 6A	Slew not working	Tripping in CP2 - no electrical problem . Informed mechanical	11:00:00	12:00:00	
5	CHP	CC 114	OLR acted (4 times)	reset done	06:40:00	12:50:00	
6	CHP	CC 203	OLR acted	reset done	07:15:00	07:30:00	
7	CHP	CC 112 , SCR 8	Reported LT and BC not running	Incomer tripped, made on	08:10:00	08:30:00	
8	CHP	CC 38 , S 1	Luff not working	Air lock problem , informed to mechanical	12:50:00	13:10:00	
9	CHP	CC 29	OLR acted (2 TIMES) .	After reset , found not running . Checked, one phase lug burn . Lug changed and trial run taken .	07:10:00	08:50:00	