



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/09/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on Co 32	LT not taking place,pCRD panel D1 relay o/g control wire loose connection	control wire tightened in Tb	08:10:00	08:28:00	
2	OHP	1-141LC3	l/c 1 tripped in under voltage	relay reset than incomer charged	06:50:00	07:05:00	
3	OHP	RSCO 10 A(c)	olr acted	reset	07:10:00	07:15:00	
4	OHP	RSCO 10 A(B)	olr acted	reset	10:00:00	10:05:00	
5	OHP	CO 32	olr acted	reset	06:30:00	06:35:00	
6	OHP	CO 15	OLr acted	reset	07:00:00	07:05:00	
7	OHP	WOBR co 25	yard interlock cage stucked up with pellets	cage released	13:30:00	13:45:00	
8	CHP	CC 111 S3	no power,power is there, b/c olr acted	olr reset	06:30:00	06:45:00	
9	CHP	CC 40 SCR 3	LT not taking place,OT acted	released	07:30:00	07:45:00	
10	CHP	CC 31 SCR4	slew and luff not working,Lt not working	Slew and luff common fuse replaced,slew limit cable damaged ,limit bypassed in i/o rack/incomer healthy bit bypass in program	10:30:00	11:30:00	
11	WT	OT 4	D1 trip in PGF1 fault	reset	08:15:00	08:20:00	