



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 25/11/2025

Area: WT

Equipment	Job
OP 6	Panel side ppm done
OP 2,3 and 6	After rake maintenance done
LC 10A	C P 1 to C P 4 panel maintenance done
EOT Crane(C)	Main Hoist ,cantactors 2C1 and 2C2 cantact kit (110A) replaced and tested ,OK