



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/10/2025

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 12 CD	OLR ACTED	RESET	12:45:00	12:55:00	
2	OHP	BRC ON CO 31	B/C OLR ACTED	RESET	06:20:00 12:50:00	06:35:00 13:00:00	
3	OHP	CO 29	OLR ACTED	RESET	07:20:00 09:05:00 11:40:00	07:25:00 09:10:00 11:45:00	
4	OHP	CO 26	OLR ACTED	RESET	09:15:00 14:00:00	09:20:00 14:05:00	
5	CHP	CC 51	FEEDING MPD TRIPPED	RESET	11:00:00	13:30:00	6 TIMES
6	CHP	CC 51	OLR ACTED	RESET	12:40:00	12:45:00	
7	CHP	CC 54	OLR ACTED	RESET	07:00:00	13:40:00	15 TIMES
8	CHP	CC 131	OLR ACTED	RESET	07:30:00 09:20:00 10:50:00	07:35:00 09:25:00 10:55:00	3 TIMES
9	CHP	CC 51 TIS	OLR ACTED	RESET	06:05:00	06:10:00	
10	CHP	SCR 3 ON CC 35	B/C TRIPPED ON SP FAULT	RESET	10:10:00	10:20:00	
11	CHP	SCR 2 ON CC 34	LUFF POWER WAS IN OFF CONDITION	MADE IT ON	11:20:00	11:30:00	
12	CHP	SCR 2 ON CC 34	B/C STOPPING FREQUENTLY DUE TO YARD RUNNING SIGNAL MISSING TO MACHINE	FEED TABLE ZSS CAGE KEPT IN CIRCUIT	12:15:00	12:30:00	
13	CHP	CC 45	OLR ACTED	RESET	11:05:00 11:20:00	11:10:00 11:25:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/10/2025

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 28	OLR ACTED	RESET	13:00:00	13:10:00	
15	WT	A4 (OT2) TRIPPING FREQUENT LY	DRIVE REPLACED	THEN OK	06:00:00	09:00:00	