



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 15/02/2026

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-1A	Reported ZSS acting	Module problem.Module replaced and tested okay	09:00:00	09:30:00	
2	OHP	WOBR on CO-29	Reported B/W not rotating	OLR acted.Reset done	09:45:00	09:55:00	
3	OHP	CO-26	Reported tripped	OLR acted.Reset done(2 times)	09:45:00	10:55:00	
4	OHP	BRC on Co-33M	Reported LT not taking place	PCRD tension acted.Released and tested okay	11:45:00	12:00:00	
5	CHP	CC-104 SCR-7	B/C stopping frequently	ZSS cage stuck with material.Made free and tested okay	10:35:00	10:50:00	
6	CHP	CC-105 SCR-10	Lt not taking place	PCRD cable found totally unwinded laying on ground.Laying done and tested okay	07:40:00	08:00:00	
7	CHP	Cc-213 SCR-9	Reported no operations taking place	ACB in off condition.Made on and tested okay	10:40:00	10:55:00	Operator pressed E-stop at cabin
8	CHP	Cc-216	Reported tripped	OLR acted.Reset done	10:40:00	10:50:00	
9	CHP	Cc -108	Reported tripped	MPD tripped.Reset done and tested okay	11:55:00	12:00:00	