



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/06/2025

Shift: C

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	00:00:00	00:10:00	
2	OHP	CO 119(C) DRIVE	MPCB TRIP	RESET	01:55:00	02:05:00	
3	OHP	RSCO 9A	OLR ACTED	RESET	05:00:00	05:10:00	
4	OHP	WOBR ON CO26	DRIVES ARE NOT RUNNING D/L ACTED	RELESED	00:30:00	00:45:00	
5	OHP	BRC ON CO 34	LT NOT TAKING PLACE DRIVE TRIP	RESET	03:00:00	03:15:00	
6	OHP	BRC ON CO 33 M	PUMP NOT RUNNING OIL LOW LEVEL	INFORMED TO OPERATION	03:15:00	03:33:00	
7	OHP	BRC ON CO 31	B/C OLR TRIPPED	RESET	00:45:00	01:00:00	
8	OHP	WOBR ON CO 6A	B/C STOPPING ON ZS CAGE STUCK UP	RELEASED	05:00:00	05:15:00	
9	OHP	CC 29	F/G MPCB TRIP	RESET	23:30:00	23:40:00	
10	CHP	CC 131	OLR ACTED(6TIMES)	RESET	23:50:00	02:40:00	DUE TO OVER LOAD
11	CHP	CC 117	OLR ACTED	RESET	04:00:00	04:15:00	
12	CHP	CC 53	STOPPING ON ZS ZS CAGE STUCK UP WITH STONE	REMOVED THAN OK	23:15:00	23:25:00	
13	CHP	CC 201	OLR ACTED	RESET	01:50:00	02:00:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/06/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 33	MPR TRIP	RESET	02:50:00	03:00:00	
15	CHP	CC 35 ON SCR 2	B/C NOT RUNNING DUE TO SIGNAL PROBLEM	LT FWD MOVED THAN OK	03:20:00	03:30:00	
16	CHP	CC 39 SCR 7	B/C NOT RUNNING	OHP SIDE POSITION SIGNAL BY PASSED	03:45:00	04:00:00	
17	CHP	CC 39 SCR 7	B/W NOT RUNNING	SPIDER RESET	03:45:00	04:00:00	
18	WT	OP 10	D6 TRIPPED	RESET DONE	23:00:00	23:10:00	
19	WT	CP 3	D 2 TRIPPED	RESET	01:45:00	02:00:00	
20	WT	CO 4(C)DRIVE	TRIPPED	RESET	00:45:00	01:00:00	