



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/07/2025

Area: IOSA

| Equipment | Job |
|--------------|---|
| BRC HARROW-2 | BRAKE PANEL CONNECTIONS GIVEN AND CHECKED THE EM BRAKE OPERATION. |
| OC-27A | LEFT REAR PULL CHORD CHECKED AS INDUCTION VOLTAGE IN RETURN WIRE TO PLC |
| MISC | OC-19A,21A,23A CONVEYOR GALLERY WELDING SOURCES, MCBDBS,SLDBS MAINTENANCE AND DEFECTS RECTIFICATION |
| WOBR-L and T | TRIAL RUN DONE AND CHECKED HYDRAULIC POWER PACK. |
| OC-11A | PPM DONE ON FIELD DEVICES. |