



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/05/2025

Shift: A

Incharge(s): V Balaji Naik, G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 28	LT not taking place/stop pb operated at panel	pb released .	12:20:00	12:35:00	
2	OHP	tbs on co 22	lt not taking place/pcrd cable tension acted	cable tension released then ok	12:10:00	12:25:00	
3	OHP	brc on co 32	bc not running/olr acted	reset done	09:45:00	09:55:00	
4	OHP	TIS ON CO 29	zss bypass request from ope.	zss bypassed at module and feed back bypassed at i/o rack	12:50:00	13:00:00	
5	OHP	tbs on co 20	right luffing not taking place/drive tripped	reset done	09:15:00	09:30:00	
6	OHP	co 5	pc acted/	pc bypassed for operation request	13:10:00	13:20:00	
7	CHP	cc24	olr acted	reset done	08:00:00	08:05:00	
8	CHP	cc 23	c/ s acted due rain	reset done	07:10:00	07:20:00	
9	CHP	cc 39 scr 7	slew not working/spider out alarm acted	reset done	08:00:00	08:10:00	
10	CHP	cc 111	brs not getting reset	probe cleaning done then reset	07:25:00	07:35:00	
11	CHP	cc 41	brs not getting reset	probe cleaning done then reset	07:45:00	08:00:00	
12	CHP	scr 8 on cc112	td elect. healthy red	glass fuse blown/fuse replaced.	06:50:00	07:00:00	xa05 -2
13	CHP	scr 8on cc 112	bc not running/c/s acted due to rain	reset done	08:30:00	08:40:00	
14	CHP	scr 8 on cc112	bw not running/oil level low	inform to ope. and mech	12:25:00	13:00:00	
15	CHP	cc 36	bc not working/bss acted	bss released	13:40:00	13:55:00	
16	CHP	cc 54	tripped on olr /due to jamming	reset done	07:30:00	13:00:00	
17	CHP	cc 131	olr acted due to jamming	reset done	09:05:00	13:30:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/05/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
18	CHP	SCR7 on Cc39	Slew not working found left limit switch acted	Limit released limit side jamming is cleared by operation	12:00:00	12:00:00	4.05 pm to 4.30pm
19	CHP	SCR2 on CC35	LT over tension acted frequently	Panel side off delay timer problem time setting changed	07:00:00	12:00:00	4.00 pm to 5.06pm
20	CHP	SCR3 on CC38	TUL kept in ckt as per operation request	kept in ckt	07:00:00	07:10:00	
21	WT	oc 1a, of 1a2a	reported red	plc power recycled @lc 9	12:00:00	12:05:00	
22	IOSA	tbs on 13a	communication problem	control wire loose at SMPS /tightend then ok	06:00:00	07:20:00	
23	IOSA	tbs on co 13a	cjd not getting reset	probe cleaning done then reset	06:00:00	06:15:00	