



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/07/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC 45	OLR ACTED	RESET	15:55:00	16:10:00	
2	CHP	CC 105 SCR 10	SIGNAL NOT SHOWING IN CCR	RECLAIMING SIGNAL REMOVED IN CM 18 THAN OK	16:05:00	16:20:00	
3	CHP	CC 105 SCR 10	SIGNAL MISSING	LT MOVED REVERSE DIRECTION THAN OK	18:00:00	18:10:00	