



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/06/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

| Sl No | Area | Equipment     | Problem                                      | Action                             | From                 | To                   | Remarks                         |
|-------|------|---------------|--|------------------------------------|----------------------|----------------------|---------------------------------|
| 1     | OHP  | WOBR on CO 6A | LT not working due to PCRD overtension       | tension released , then ok         | 06:50:00             | 07:05:00             |                                 |
| 2     | OHP  | V F 2A        | Drive tripped due to coal side motor burn    | Motor changed                      | 07:00:00             | 14:00:00             | Informed operation for cleaning |
| 3     | OHP  | TT 2 on CO 21 | Position indication not coming               | Fuse TB loose , connected properly | 07:25:00             | 07:35:00             |                                 |
| 4     | OHP  | CO 77         | Overload acted                               | reset done                         | 13:15:00             | 13:20:00             |                                 |
| 5     | OHP  | CR 1A         | Stopping on high vibration                   | Vibration showing 50 continuously  | 13:00:00             | 13:30:00             | Informed to instrumentation     |
| 6     | CHP  | CC 39 , SCR 7 | BW not running                               | Fault reset done in operator cabin | 07:10:00             | 07:20:00             |                                 |
| 7     | CHP  | CC 32 , SCR 5 | BC not running                               | Fault reset done in operator cabin | 07:45:00             | 07:50:00             |                                 |
| 8     | CHP  | CC 39 , SCR 7 | LT not working due to PCRD overtension acted | tension released , then ok         | 10:55:00             | 11:10:00             |                                 |
| 9     | CHP  | CC 33         | Tripped in overload                          | reset                              | 12:05:00<br>12:40:00 | 12:15:00<br>12:45:00 |                                 |
| 10    | CHP  | CC 32         | Tripped in overload                          | reset                              | 12:15:00             | 12:20:00             |                                 |
| 11    | CHP  | CC 201        | Tripped in overload                          | reset done                         | 12:25:00             | 12:30:00             |                                 |
| 12    | CHP  | CC 54         | Tripped in overload                          | reset done                         | 09:15:00             | 09:20:00             |                                 |
| 13    | CHP  | CC 131        | Tripped in overload                          | reset done                         | 13:40:00             | 13:45:00             |                                 |



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/06/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

| Sl No | Area | Equipment                  | Problem                                 | Action                | From     | To       | Remarks |
|-------|------|----------------------------|---|-----------------------|----------|----------|---------|
| 14    | WT   | OP 7                       | Not moving , individual breaker tripped | made on               | 10:00:00 | 10:15:00 |         |
| 15    | WT   | CP 2 and CP 4              | Communication problem                   | PLC recycled at cabin | 11:20:00 | 11:40:00 |         |
| 16    | WT   | 7A / 5A material selection | 5a kept in dolo                         | At LC 1               | 11:00:00 | 11:10:00 |         |