



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/06/2025

Shift: C

Incharge(s): Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 30	LT not moving due to pcrd overtension	tension released	00:45:00	01:00:00	
2	OHP	TT 1 on CO 21	Position bit missing	Fuse blown at CJB . Replaced	22:20:00	22:35:00	
3	CHP	CC 34 , SCR 2	PCRD guide problem	After mechanical guide adjustment done pcrd winded properly	23:50:00	00:20:00	
4	CHP	CC 33 , SCR 4	Slew problem	Fault reset done	01:50:00	02:10:00	
5	CHP	CC 104 , SCR 9	BW not running	Fault reset done	00:30:00	00:45:00	
6	CHP	CC 36 , SCR 1	LT not working	Drive reset . Also found cable in zig zag condition . Winding done properly	04:30:00	04:55:00	
7	CHP	CC 51	Stopped on Zero speed	Material overload on belt , informed to operation	23:45:00	23:50:00	
8	CHP	CC 131	Tripped on overload (3 times)	reset done	02:05:00	05:30:00	
9	CHP	RG 3	Flapgate motor tripped	reset	03:00:00	03:05:00	
10	CHP	CC 131	Stopped on ZSS	Material overload on belt and off centering . Informed to operation and mechanical	04:50:00	05:35:00	
11	CHP	CC 125	Reported not running	Checked, motor running but belt not moving . Informed to mechanical	02:15:00	02:25:00	