



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 8A	CT not taking place,MCCB is in off	made it on	16:30:00	16:40:00	
2	OHP	CO 50	olr acted	reset	17:30:00	17:45:00	
3	OHP	CO 26	olr acted	reset	19:20:00	19:30:00	3 times
4	OHP	TBS on co 5A	LT not taking place,M3 OLR acted	reset	20:40:00	20:55:00	
5	CHP	CC 46	OLr acted	reset	14:10:00	14:20:00	
6	CHP	CC 105 scr10	slew not working,return filter block 1 unhealthy	filter handle changed	18:00:00	18:10:00	
7	CHP	CC 51	MPD tripped 8 times	reset	15:15:00	19:30:00	
8	CHP	CC 54	olr acted	reset	15:20:00	15:25:00	
9	CHP	CC 52	mpd tripped 2 times	reset	15:30:00	16:35:00	