



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/05/2025

Shift: B

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 35	tripped on tharmal olr acted 3 times due more material	reset done	16:25:00 17:40:00 18:15:00	16:30:00 17:45:00 18:20:00	
2	OHP	co 62 b/d	tripped on mpcb due jamming	mpcb made on	17:00:00	17:15:00	
3	OHP	brc on co 34 (FLsmith)	It not taking place/drive tripped	reset done	19:35:00	19:45:00	
4	OHP	co 26	tripped on olr	reset done	19:15:00 21:10:00	19:25:00 21:20:00	
5	OHP	co 34	tripped on olr	reset	15:30:00	15:40:00	
6	CHP	cc 132	brs acting /loose connection at module tb.	terminals tightend then ok	14:40:00	15:10:00	
7	CHP	s 1 on cc35	It not taking place pcrd cable tension acted	cable tension released.	16:20:00	16:35:00	
8	CHP	cc 52	zss acting due heavy load on the conv.	kept in DOL mode and clear the material then again in drive mode	16:30:00	16:50:00	
9	CHP	scr 2on cc34	luffing not taking place	power and control recycled then ok	14:45:00	15:00:00	
10	CHP	scr 9 on cc104	slew not working/slew limit acted	reset done	14:55:00	15:20:00	
11	CHP	scr 10 on cc105	slew not working/mpd tripped on earth fault	reset done	15:45:00	16:00:00	
12	CHP	scr 1 on cc36	bw not working/mpd tripped on oc	reset	16:20:00	16:30:00	
13	CHP	cc 117	tripped on olr	reset done	18:10:00	18:15:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/05/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	cc 48	zss acting/no power to module	cable loose in panel tb/tightend then ok (RL 25)	19:45:00	20:00:00	
15	CHP	CC 114	tripped on olr	reset	18:30:00	18:40:00	
16	CHP	cc 131	trippedon olr	reset	20:45:00	20:55:00	
17	WT	op 9	pusher reached ded zone while reverse after rake	kepet in parking zone	20:30:00	20:50:00	no delay