



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/11/2025

Area: OHP

Equipment	Job
rco-1a and rco-2a chute sensors	cjd's are programmed as to stop then conveyer when its respective directions cjd is acted. and indication provided in ocr hmi.