



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/10/2025

Area: WT

Equipment	Job
OT 1	Hopper light fittings glass cleaning done
OP 1	Checked all drives in de clutch position ,foun D1 and D2 cascade problem ,rectified it
EOT Crane(O)	Checked all CT,LT,MH and AH in local and remote ,Main Hoist lower not OK in LOCAL,rectified
OP 2,3,5 and 7	After rake maintenance done